


Technical drawing of a manhole structure, showing a cross-section and a plan view. The drawing includes the following labels and dimensions:

- материя минераловатные** (mineral wool material) - points to the insulation layer.
- Асбест $\delta = 5 \text{ мм}$** (Asbestos $\delta = 5 \text{ мм}$) - points to the asbestos lining.
- лист Б,06 ГОСТ19903-71** (sheet B,06 GOST 19903-71) - points to the concrete structure.
- СТК ГОСТ17715-72** (STK GOST 17715-72) - points to the concrete structure.
- Ду 150** (DN 150) - indicates the diameter of the manhole opening.
- Обить жестью по асбесту** (cover with lead over asbestos) - points to the lead lining.
- Асбест $\delta = 5 \text{ мм}$** (Asbestos $\delta = 5 \text{ мм}$) - points to the asbestos lining.
- Люк для прочистки** (manhole for cleaning) - points to the access point.
- не менее 250** (not less than 250) - indicates the minimum height of the structure.



							Реконструкция котельной ПАЗС в п.Кысыл-Сыр Вилуйского улуса		
ГИП	Аммосова		Внутренние сети газоснабжения				Стадия	Лист	Листов
Проверил	Федоров						РП		
Исполнил	Иванова								
			Дымоход					Проектно-конструкторское бюро ОАО "ЯТЭК"	

A3